



District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), Ballia

Office of Executive Engineer, Construction division, U.P Jal Nigam, Opposite SMTD College, Ballia. Pin- 277001 (Test Address only)

Test report

Sample Id:

U1141767S35792182

User Information

Name:	Nitil kumar Bharti	Mobile:	8423413813
Email:	nitilkumar8423@gmail.com	Pin Code:	0
Full Address:	Village- Not available , Gram Panchayat- Not available, Block- Not available, District- Ballia, State- Uttar Pradesh		

Sample description

Source of Sample:	Others, location :	Village:	Malipur
Gram Panchayat:	Malipur	Block:	Nagra
District:	Ballia	State:	Uttar Pradesh
Address:		Remarks:	Bharti Gyandeep Public School Sahdev Nagar Naurangiya Malipur Nagra Ballia Sample Submitted By Ar
Latitude:	26.041894	Longitude:	83.862482

Date & time of sample collection

26.03.2026 | 03:18:00 PM

Date & time of sample received in lab

01.04.2026 | 10:10:00 AM

Date & time of sample analysed

01.04.2026 | 02:00:00 PM

Date & time of report generation

01.04.2026 | 03:43:36 PM

Test results

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Chloride (as Cl)*	mg/l	250	1000	6.990	Argentometric method	
2	Fluoride (as F)*	mg/l	1	1.5	0.025	Ion selective electrode method	
3	Iron (As Fe)*	mg/l	1	No Relaxation	0.280	Phenanthroline method or as per IS 15303:2002 Electrothermal atomic absorption/Spectrophotometer method	
4	Nitrate (as NO3)*	mg/l	45	No Relaxation	2.480	UV-Visible Spectrophotometer	
5	pH*	NA	6.5-8.5	No Relaxation	7.650	Electrometric method	
6	Sulphate (as SO4)*	mg/l	200	400	8.210	Turbidimetric method	
7	TDS*	mg/l	500	2000	232.000	Gravimetric method	
8	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	148.000	Titration method	
9	Total Hardness (As CaCO3)*	mg/l	200	600	136.000	Titration method	
10	Turbidity*	NTU	1	5	1.060	Nephelometric method	

Note:

- 1)*indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Data prepared by

Chemist: (Shiv Shankar Aggarwal)

Authorised signatory

Ashutosh Kumar Giri (Test Lab Incharge)

*****This is an electronically generated report and does not require a signature.*****

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC. Copyright ©copy NJJM 2026

Annexure C

.PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 30.06.2026

It is certified that an inspection team headed by Dr. Rakesh Kumar Singh Medical Officer CHC Siar
from Public Health Department PHED

inspected Bharti Gyandeep Public School Naurangiya, Malipur, Ballia (U.P)

on 01/05/2026 and on the basis of water Test Report bearing
no U1141767S3579182 Dated 01/04/2026 of District Level Water Analysis Laboratory U.P. Jal Nigam
(Rural), Ballia

certified that the Bharti Gyandeep Public School safe drinking water facilities for the students and
members of staff of the institution. School is also maintains the hygienic sanitation condition in the school
building & the campus as per norms prescribed by the Central/ State/ U. T. Govt.

This certificate is valid till 1 Year

Signature with Seal: _____

Name: Rakesh Kumar Singh

Medical Officer
CHC Siar,
Ballia

Designation: Medical Officer

Name & Address of the office Department : CHC Siar, Ballia

To Bharti Gyandeep Public School

Naurangiya, Malipur, Ballia (U.P)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

